

## Food Premises Inspection Summary Report

<b>Name of Premise:</b>	Under One Sky	<b>Licence #:</b>	03-039731
<b>Address:</b>	7 Leverman Street Fredericton NB E3A 4H3	<b>Type:</b>	Class/Classe 4
<b>Water Supply:</b>	Municipal	<b>Category:</b>	Pre-Operational
		<b>Date of Inspection:</b>	January 29, 2024

*MI - Minor infraction; MA - Major infraction; CR - Critical infraction; CDI - Corrected During Inspection; N/A - Not Applicable*

### OBSERVATIONS AND CORRECTIVE ACTIONS

Item	MI /MA/ CR	Remarks	Date for Correction
10.3	MI	Ceilings shall be of sound construction and in good repair. <b>Observations: False ceiling constructed out of raw unfinished wood is located above the handwashing sink.</b> <b>Comment: Paint or apply a finish to the ceiling so it can be easily cleaned.</b>	Immediately

### CLOSING COMMENTS

Recommended for licensing.

**Rating colour: Green**