

Food Premises Inspection Summary Report

Name of Premise:	Sour Grape	Licence #:	03-00723
Address:	281 Restigouche Road Oromocto NB E2V 2H1	Type:	Class/Classe 4
Water Supply:	Municipal	Category:	Routine Compliance
		Date of Inspection:	January 23, 2024

MI - Minor infraction; MA - Major infraction; CR - Critical infraction; CDI - Corrected During Inspection; N/A - Not Applicable

OBSERVATIONS AND CORRECTIVE ACTIONS

Item	MI /MA/ CR	Remarks	Date for Correction
12.2	MI	<p>Outstanding Infraction: Effective ventilation shall be provided to areas of the premises that are subject to the generation or accumulation of odours, fumes, steam, vapors, smoke or excessive heat.</p> <p>Comment: This issue was previously noted on January 9, 2024. The fire inspection is soon to be conducted by a fire prevention officer and the operator will ask for clarification whether a range hood is required and recommend minimum size, if necessary.</p>	January 23, 2024

CLOSING COMMENTS

All outstanding infractions are to be corrected at the next routine inspection.

Rating colour: Green